CERTIFICATE

No. 2P250808.ACQC07

Technical File No.: ARVO/TCF/1, Rev.: 00, Date: 15/07/2025

Certificate's ARVO CONTROLS SOCIEDAD LIMITADA

Holder: Cami de la Alquerieta, Parcela, R-114A, Massanassa - 46470, Valencia, Spain

Certification ECM Mark



Product: Fire Pump Controller

Model(s): Electric Fire Pump Controller

Diesel Engine Fire Pump Controller

Jockey Pump Controller

Verification to: Standard:

(see the following annex)

related to CE Directive(s): 2014/35/EU (Low Voltage)

2014/30/EU (Electromagnetic Compatibility)

Remark:

The manufacturer has voluntarily decided to submit its documents concerning the above-mentioned product for verification. Ente Certificazione Macchine confirms that the documentation made available and immediately returned to it, as containing sensitive data, meets the essential requirements of the above-mentioned directive/standard. The verification activity carried out exclusively concerned the technical documentation and no verification was carried out on the product. This document cannot replace the EC Declaration of Conformity. This document was issued in accordance with regulation RGVOL01 published on the website of www.entecerma.it and concerning voluntary certifications with a non-notified procedure.

Issuance date: 08 August 2025 Expiry date: 07 August 2030

For online check:



Approver
Ente Certificazione Macchine
Legal Representative
Luca Bedonni



Annex I

No. 2P250808.ACQC07

Technical File No.: ARVO/TCF/1, Rev.: 00, Date: 15/07/2025



Standard:

IEC 61439-1:2020, IEC 61439-2:2020, IEC 60204-1:2021, IEC 60947-1:2020, IEC 60529:1989/AMD2:2013/COR1:2019, EN IEC 61000-6-2:2016, EN IEC 61000-6-3:2020, EN IEC 61000-6-4:2018, IEC 62091:2007, IEC 61000-4-2:2025, IEC 61000-4-3:2020, IEC 61000-4-4:2012, IEC 61000-4-5:2014, IEC 61000-4-6:2023, IEC 61000-4-8:2009, IEC 61000-4-11:2020, CISPR 11:2024

